



Science and
Technology
Facilities Council

ITRF - LhARA

General Facility Infrastructure and Integration


ITRF WP2 & LhARA WP1.6

1272-pa1-wp2-prs-0010-v1.0-ITRF-24-month-design-review-WP6-infrastructure-2024-09-02

24 Month Design Review

2nd September 2024




Clive Hill, UKRI-STFC-Daresbury Laboratory, On behalf of the team





71m

Facility Layout Ground Floor

32m




Concrete Bunker Shielding




Concrete Shielding Thickness (Assumptions)


| | |
|--------------------|------|
| Target and Capture | 0.5m |
| Low Energy Line | 0.5m |
| FFA Area | 1.0m |
| High Energy Line | 1.0m |
| In Vivo Station | 1.0m |





Facility Layout First Floor




Facility Layout Second Floor







Low Energy Line





Stage 1 Low Energy Line






Tape Target







Diagnostics Camera




Low Energy Line



Low Energy Line Support Systems



Low Energy Line Support Systems Example




Lifting points

Kinematic supports

Support Beam


Support Pedestal

FFA Injection Line & Ring Magnet Yoke





Preliminary LhARA FFA magnet specification:


lattice : spiral scaling singlet,
 N: 10,
 ksi: 48.7 degree,
 R0: 3.477m,
 Rmax: 3.53m,
 Rmin: 2.88m,
 Gap: 9.5cm.




FFA Magnet




Trim coils only shown
on lower pole




Trim Coils




Single trim coil wound with $\square 10\text{mm}$ conductor with $\text{\O}6\text{mm}$ hole





9 coils in each layer




Single trim coil wound with $\square 10\text{mm}$ conductor with $\text{\O}6\text{mm}$ hole




9 coils in each layer




Braze connector blocks for water and electrical connections






Braze connector blocks for water and electrical connections





9 coils in each layer



Ring Vacuum Chamber – Stainless Steel



Ring Vacuum Chamber – Finite Element Analyses by Mitchell Kane



The following success criteria were used:

- Maximum stress less than 2/3 yield, i.e., yield safety factor of 1.5
- Maximum deflection < 2mm




Yield safety factor is defined as:

$$\text{Yield safety factor} = \frac{\text{Yield stress}}{\text{Stress}}$$

Yield safety factors are used for easier comparisons between materials. It is clearer to determine whether stresses are acceptable without having to refer back to the yield stress for each material.



A: As modelled 315-10176

Safety Factor
Type: Safety Factor
Time: 1
29/07/2024 12:14





C: As modelled 315-10176-WIPA.4

Safety Factor
Type: Safety Factor
Time: 1
08/08/2024 14:47




RF Cavity




FFA MA Cavity

FFA Ring - spiral angle 53.9 degrees





Spiral angle 48.7 degree

Spiral angle 53.9 degree



High Energy Line



Questions

Any questions that cannot be answered by the team in attendance can be sent to myself at

clive.hill@stfc.ac.uk

Thank you